

Herstellereklärung zur  
EG-Richtlinie 2014/34/EU (ATEX)

EPI-Kugelhähne  
Typenreihe VLA

Die oben aufgezählten Armaturen wurden einem Konformitätsbewertungsverfahren nach der Richtlinie 2014/34/EU mit folgendem Ergebnis unterzogen:

Die Armaturen besitzen keine potentielle Zündquelle.

Sie fallen nicht in den Anwendungsbereich der ATEX Richtlinie 2014/34/EU. Die Armaturen dürfen im EX-Bereich eingesetzt werden.

Ergänzender Hinweis:  
Elektrische/mechanische Antriebe müssen einer eigenen Konformitätsbewertung nach ATEX unterzogen werden.

Verweis auf Normen und Regelwerke:

EN ISO 80079-36:2016  
EN ISO 80079-37:2016

Ettlingen

14.6.2022

Datum / Date

Manufacturer's Declaration to the  
European Directive 2014/34/EC  
(ATEX)

EPI Ball valve  
series VLA

For the above listed ball valves a assessment of conformity to code 2014/34/EC was executed with the following result:


These ball valves hold no potential ignition source.

They did not fall under the scope of the ATEX directive 2014/34/EC. The valves may be used in the EX-range.

Supplementary note:  
Electrical/mechanical actuators have to undergo a separate assessment of conformity.

Reference to Standards:

EN ISO 80079-36:2016  
EN ISO 80079-37:2016

  
Peter W. Hurst  
Geschäftsführer / Manager